


STORE 36068 | RISO 36068 | None | TABLE PAGE 1/1

1005 s main st | Kernersville, Nc, 27284 | TANKS 3
REG T4 19,782 gal READY/MANUAL_VERIFIED 118" N=3 LOW | PRE T5 7,901 gal READY/MANUAL_VERIFIED 118" N=2 LOW |
DIE T6 11,904 gal READY/MANUAL_VERIFIED 119" N=2 LOW

INCHES	REG T4 (118") N=3	PRE T5 (118") N=2	DIE T6 (119") N=2	INCHES	REG T4 (118") N=3	PRE T5 (118") N=2	DIE T6 (119") N=2
1	26	10	16	61	10,346	4,138	6,118
2	74	30	44	62	10,560	4,223	6,245
3	136	54	80	63	10,773	4,308	6,372
4	208	83	123	64	10,986	4,394	6,498
5	290	116	171	65	11,199	4,479	6,625
6	380	152	224	66	11,412	4,564	6,751
7	478	191	282	67	11,624	4,649	6,878
8	582	233	343	68	11,836	4,733	7,003
9	693	277	409	69	12,047	4,818	7,129
10	810	324	477	70	12,257	4,902	7,254
11	932	373	549	71	12,467	4,986	7,379
12	1,059	424	624	72	12,676	5,069	7,504
13	1,190	476	702	73	12,884	5,152	7,628
14	1,327	531	782	74	13,091	5,235	7,751
15	1,467	587	865	75	13,297	5,317	7,874
16	1,612	645	951	76	13,503	5,399	7,996
17	1,760	704	1,038	77	13,707	5,481	8,118
18	1,912	765	1,128	78	13,910	5,562	8,240
19	2,068	827	1,220	79	14,111	5,643	8,360
20	2,227	891	1,314	80	14,312	5,723	8,480
21	2,390	956	1,410	81	14,511	5,802	8,599
22	2,555	1,022	1,507	82	14,708	5,881	8,717
23	2,723	1,089	1,606	83	14,904	5,959	8,834
24	2,894	1,158	1,707	84	15,098	6,037	8,951
25	3,068	1,227	1,810	85	15,291	6,114	9,066
26	3,244	1,298	1,914	86	15,482	6,190	9,181
27	3,422	1,369	2,020	87	15,671	6,266	9,294
28	3,604	1,441	2,126	88	15,858	6,340	9,406
29	3,787	1,515	2,235	89	16,043	6,414	9,518
30	3,972	1,589	2,344	90	16,225	6,487	9,628
31	4,160	1,664	2,455	91	16,406	6,559	9,736
32	4,349	1,740	2,567	92	16,584	6,630	9,844
33	4,540	1,816	2,680	93	16,760	6,700	9,950
34	4,733	1,893	2,794	94	16,932	6,769	10,055
35	4,928	1,971	2,909	95	17,103	6,837	10,158
36	5,124	2,050	3,025	96	17,270	6,904	10,260
37	5,322	2,129	3,142	97	17,435	6,970	10,359
38	5,521	2,208	3,260	98	17,596	7,034	10,458
39	5,722	2,289	3,379	99	17,755	7,097	10,554
40	5,924	2,370	3,498	100	17,910	7,159	10,649
41	6,127	2,451	3,618	101	18,061	7,219	10,742
42	6,332	2,532	3,739	102	18,208	7,278	10,832
43	6,537	2,615	3,861	103	18,352	7,336	10,921
44	6,744	2,697	3,983	104	18,492	7,391	11,007
45	6,951	2,780	4,106	105	18,627	7,445	11,091
46	7,159	2,864	4,229	106	18,758	7,497	11,172
47	7,369	2,947	4,353	107	18,883	7,547	11,251
48	7,578	3,031	4,477	108	19,004	7,595	11,327
49	7,789	3,115	4,602	109	19,119	7,641	11,400
50	8,000	3,200	4,727	110	19,228	7,684	11,470
51	8,212	3,284	4,852	111	19,331	7,725	11,537
52	8,424	3,369	4,978	112	19,427	7,763	11,600
53	8,637	3,454	5,104	113	19,516	7,798	11,659
54	8,850	3,540	5,230	114	19,595	7,829	11,714
55	9,063	3,625	5,357	115	19,666	7,856	11,765
56	9,277	3,710	5,484	116	19,724	7,879	11,810
57	9,490	3,796	5,610	117	19,768	7,896	11,849
58	9,704	3,881	5,737	118	19,785	7,901	11,880
59	9,918	3,967	5,864	119			11,902
60	10,132	4,052	5,991				

STORE 36068 | RISO 36068 | None | COMBINED GRAPH
1005 s main st | Kernersville, Nc, 27284 | TANKS 3
REG T4 19,782 gal READY/MANUAL_VERIFIED 118" N=3 LOW | PRE T5 7,901 gal READY/MANUAL_VERIFIED 118" N=2 LOW |
DIE T6 11,904 gal READY/MANUAL_VERIFIED 119" N=2 LOW



Generated 2026-10-28 02:41 UTC | Store-wide chart for 3 tanks | 7 total Veeder observations | Trust threshold N>=10 | LOW CONFIDENCE T4=3, T5=2, T6=2